

South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

February 24, 2009
Via Electronic Mail

Mr. Gerardo C. Rios
Chief – Permits Office
US EPA Region IX
75 Hawthorne Street, Air 3
San Francisco, CA 94105

Dear Mr. Rios:

Enclosed is the proposed Title V permit revision (Draft – Section D, Pages 37-45) for the facility listed below, for your 45 day review and commenting period.

Facility ID #	Facility Name	Address
800236	Los Angeles County Sanitation Districts – Joint Water Pollution Control Plant	24501 S. Figueroa St., Carson, CA 90745-6311

The proposed Title V permit is revised under applications 467057, 467059, and 467060 by the functionally identical replacements of heat recovery steam generators associated with the three existing combustion turbines. The gas turbines will not undergo change and thus all emission rates will be unaltered. The air quality will be positively impacted due to the increase in stack height and temperature relative to the current system. The proposed modifications therefore do not result in increased emissions of criteria pollutant subject to New Source Review or HAP.

The proposed permit revisions are considered a “de minimis significant permit revision” to the initial Title V permit (Revision #0) issued on January 12, 2009. A public notice is not required.

If there are specific questions on the revised permit, please contact Amir Dejbakhsh, at 909-396-2618, prior to the closing date of the review period.

Sincerely,



Jay Chen, P.E.
Senior Engineering Manager
Refinery and Waste Management Permitting

JC:CDT:AD

cc: Victoria Conway, LACSD